Energies Constant Con



MODEL NO: 62021

DESCRIPTION

Hospital grade receptacles meet UL hospital grade requirements. In addition to complying with the general use receptacle listing requirements, hospital grade devices incorporate additional construction features and are subjected to additional performance requirements. These include grounding reliability, assembly integrity and strength and durability tests.

FEATURES	SPECIFICATIONS		
 Impact resistant thermoplastic cover and body Ground termination-brass strap version Break-off tabs for easy two-circuit conversion Two side barriers cover the wire terminals for insulation and isolation function Use only with 10AWG to 14AWG wires 	Amperage Voltage NEMA Termination Material Operating Temperature Warranty	20 Amp 250VAC 6-20R Back Wired Thermoplastic -104° F to 167° F 2 Years	

TESTING & CODE COMPLIANCE



APPLICATIONS

- Health Care Facilities
- Hospitals
- Laboratories

SPECIFICATION SUBMITTAL

Control. Charge. Connect.	() www.enerlites.com	▲1 (9/9) 754-0534	;; +1 (949) 756-0528	Sales@enerlites.com	REV-20230802
Notes		_			
Job Name			Job Number		